TEST RESULTS OF GRADATION FOR GSB
(IS 2386:(Part 1) 1963 (RA2011)

Lab ID	:	**CP-RW-2017-12-27-01** **Date: 29-12-17**
Customer	:	Assistant Executive Engineer, Vidyaranyapura Sub Division, BBMP, Bangalore.
Address	:	Vidyaranyapura Sub Division, BBMP, Bangalore.
Project Name	:	Improvements to roads and drains at Narasipura in ward no.09(Vidyaranyapura).
Agency	:	Executive Engineer, KRIDL, #280, 59th Cross road, 17th 'C' Main road, 3rd 'Y' Block, Rajajinagara, Bangalore-560 010.
Customer Reference	:	BBMP/EE/BTP/WO/ /2017-18
Source of Sample	:	Sample supplied by Agency
Sample Condition	:	Satisfactory
Date of Receipt	:	27-12-17
Sample ID No	:	2017-12-27-01/01
Type of Mix	:	GSB (Granular Sub Base)
Date of test	:	27-12-17
Oven Dry Weight	:	10120 Grams

IS Sieve Size(mm)	Weight Retained (gm)	Cumulative Weight Retained (gm)	% Cumulative Weight Retained	% Passing	Spec. Limit Vide Table 400.1 MORTH Specification
75	0	0	0.0	100.0	100
53	996	996	9.8	90.2	80-100
26.5	1686	2682	26.5	73.5	55-90
9.5	1292	3974	39.3	60.7	35-65
4.75	1490	5464	54.0	46.0	25-55
2.36	1764	7228	71.4	28.6	20-40
0.425	1666	8894	87.9	12.1	10-25
0.075	896	9790	96.7	3.3	0-5

TESTS ON FILLER SCREEN MATERIALS

Sl no	Particulars	Test results	Spec.Limit Vide Table 400.2 MORTH Specification
1	Liquid Limit, %	21.33%	Maximum 25
2	Plasticity index, %	Non plastic	Maximum 6

Note:-
The results pertain to the samples received and tested.
All information Furnished by Customer/ Representative
Any correction in the report will make this report invalid.
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 30 days from the date of issue of test certificate

AE

CIVIL Pro Sig..... Date..... BANGALORE

FOR CIVIL Pro.
R KARTHIK RECHAN
Authorized Signatory
Quality Manager

End of Report

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com